

## Water quality test results

Inspection Agency	Shin Nihon Kentei Kyokai
Place of Sampling	MASHIMIZU MARU
Sample	Drinking Water
Date of Sampling	January 14, 2026
Date of Examination	January 14 to 26, 2026

Test items	The water quality standard	Results
Standard Plate Count(S.P.C)	100 and less CFU/mL	0 CFU/mL
Escherichia coli	not to be detected	nondetection
Nitrite Nitrogen	0.04 and less mg/L	less than 0.004 mg/L
Nitrate nitrogen and nitrite nitrogen	10 and less mg/L	0.7 mg/L
Chloride	200 and less mg/L	5.6 mg/L
Total Organic Carbon	3 and less mg/L	less than 0.3 mg/L
pH Value	5.8～8.6	7.8
Taste	not abnormal	normal
Odor	not abnormal	normal
Color	5 and less degree	less than 1 degree
Turbidity	2 and less degree	less than 0.5 degree
Residual chlorine	—	0.1 mg/L
Judgment	The above-mentioned test result suits the water quality standard of Water Supply Act.	

1 Test method(s): Ministry of Health, Labour and Welfare notification No.261.

2 The judgment based on the water quality standard of Water Supply Act.(Ordinance of Ministry of Health, Labour and Welfare No.101)