

## Water quality test results

Inspection Agency	Shin Nihon Kentei Kyokai
Place of Sampling	MASHIMIZU MARU
Sample	Drinking Water
Date of Sampling	February 5, 2026
Date of Examination	February 5 to 20, 2026

Test items	The water quality standard	Results
Standard Plate Count(S.P.C)	100 and less CFU/mL	0 CFU/mL
Escherichia coli	not to be detected	nondetection
Nitrite Nitrogen	0.04 and less mg/L	less than 0.004 mg/L
Nitrate nitrogen and nitrite nitrogen	10 and less mg/L	0.7 mg/L
Chloride	200 and less mg/L	5.6 mg/L
Total Organic Carbon	3 and less mg/L	less than 0.4 mg/L
pH Value	5.8~8.6	7.3
Taste	not abnormal	normal
Odor	not abnormal	normal
Color	5 and less degree	less than 1 degree
Turbidity	2 and less degree	less than 0.5 degree
Residual chlorine	—	0.3 mg/L

Judgment

The above-mentioned test result suits the water quality standard of Water Supply Act.

1 Test method(s): Ministry of Health, Labour and Welfare notification No.261.

2 The judgment based on the water quality standard of Water Supply Act.(Ordinance of Ministry of Health, Labour and Welfare No.101)