

Water quality test results

Inspection Agency	Shin Nihon Kentei Kyokai
Place of Sampling	MASHIMIZU MARU
Sample	Drinking Water
Date of Sampling	July 1, 2025
Date of Examination	July 1 to 18 ,2025

Test items		The water quality standard	Results
Standard Plate Count(S.P.C)		100 and less CFU/mL	59 CFU/mL
Escherichia coli		not to be detected	nondetection
Nitrite Nitrogen		0.04 and less mg/L	less than 0.004 mg/L
Nitrate nitrogen and nitrite nitrogen		10 and less mg/L	0.6 mg/L
Chloride		200 and less mg/L	6.1 mg/L
Total Organic Carbon		3 and less mg/L	0.6 mg/L
pH Value		5.8～8.6	7.8
Taste		not abnormal	normal
Odor		not abnormal	normal
Color		5 and less degree	less than 1 degree
Turbidity		2 and less degree	less than 0.5 degree
Residual chlorine		—	less than 0.1 mg/L
Judgment	The above-mentioned test result suits the water quality standard of Water Supply Act.		
1 Test method(s): Ministry of Health, Labour and Walfare notification No.261.			
2 The judgment based on the water quality standard of Water Supply Act.(Ordinance of Ministry of Health, Labour and Walfare No.101)			