

Water quality test results

Inspection Agency	Shin Nihon Kentei Kyokai
Place of Sampling	MASHIMIZU MARU
Sample	Drinking Water
Date of Sampling	November 4, 2025
Date of Examination	November 4 to 18 ,2025

Test items	The water quality standard	Results
Standard Plate Count(S.P.C)	100 and less CFU/mL	0 CFU/mL
Escherichia coli	not to be detected	nondetection
Nitrite Nitrogen	0.04 and less mg/L	less than 0.004 mg/L
Nitrate nitrogen and nitrite nitrogen	10 and less mg/L	0.8 mg/L
Chloride	200 and less mg/L	5.9 mg/L
Total Organic Carbon	3 and less mg/L	less than 0.3 mg/L
pH Value	5.8~8.6	7.2
Taste	not abnormal	normal
Odor	not abnormal	normal
Color	5 and less degree	less than 1 degree
Turbidity	2 and less degree	less than 0.5 degree
Residual chlorine	—	0.5 mg/L

Judgment	The above-mentioned test result suits the water quality standard of Water Supply Act.
----------	---

1 Test method(s): Ministry of Health, Labour and Walfare notification No.261.

2 The judgment based on the water quality standard of Water Supply Act.(Ordinance of Ministry of Health, Labour and Walfare No.101)